

ADSC Southeastern Chapter Drilled Shaft Research Project

LOAD TESTING OF DRILLED SHAFT FOUNDATIONS IN
PIEDMONT ROCK
LAWRENCEVILLE, GA

Robert Thompson, P.E., D.GE
Dan Brown and Associates, PC


Georgia Section ASCE Geotechnical Group
November 15, 2011




Site Characterization

TODD BARBER, P.E.
GEO-HYDRO ENGINEERS, Inc.


Planned Test Shafts




RQD from Rock Cores



Compressive Strength of Rock





Planned Test Shafts




Planned Test Shafts


Test Shaft 2 – 66in Shaft to Rock Auger Refusal with 16in O-Cell on 20in Bearing Plate




Actual Test Shaft 1



Actual Test Shaft 2



O-Cells



34in O-Cell (Test Shaft 1)



16in O-cell with 20in base plate (Test Shaft 2)



Test Day



Test Results – Unit Side Resistance

- Limit of the O-cell was reached
 - TS 1 = 8900 kips (34in cell)
 - TS 2 = 1850 kips (16in cell)
- USR vs displacement curves indicate tests were close to maximum.
- Significant resistance was mobilized in the gneiss at small displacement (0.2in or less).



Test Results – Unit Side Resistance





Table 3 – Maximum Average Unit Side Resistance

Shaft	Material	Maximum Unit Side Shear (ksf)	Normalized Displacement (% Diameter)
1	Gneiss Rock	52	1.5
1	PWR	15	1.5
2	Soft PWR (Upper PWR)	2.5	0.5

≈ 0.6in

≈ 0.3in

Test Results – Unit Side Resistance



Test Results – Unit Base Resistance

- Limit of the O-cell was reached
- UBR vs displacement curves indicate TS 1 had more to give, TS 2 close to maximum.
- TS 1 factor out side resistance of 2ft plug below cell
- TS 2 projected area through seating layer bearing on rock

Test Results – Unit Base Resistance




Table 4 – Maximum Unit Base Resistance

Shaft	Material	Maximum Unit Base Resistance (ksf)	Normalized Displacement (% Diameter)
1	Gneiss Rock	850	4
2	Gneiss Rock	600	10

≈ 1.6in

≈ 2in


Other Atlanta Area Tests

Table 5 – Load Tests in Atlanta Area in Similar Geology

Site	Shaft Dia. (in)	Material	Unit Side Resistance (ksf)	Normalized Displacement (%D)	Unit Base Resistance (ksf)	Normalized Displacement (%D)
A	56.5	PWR (sampled as sand with silt and rock fragments)	2	1.8	70	6.7
B	48	PWR (sampled as micaceous silty sand)	2.8	1.9		
		Weathered gneiss (RQD = 50%)	12.2	2.1	233	1.5
C	48	PWR (weathered gneiss (RQD = 24% and sandy silt))	6.8	5.8		
			5.5	2.1		
	36	Weathered gneiss (RQD = 49%)			449	2.5




Other Atlanta Area Tests – Unit Side Resistance




Other ATL Tests Observations – Unit Side Resistance

- 2 to 12.2 ksf at 1.8 to 2.1% normalized displacement.
- Site A likely influenced by installation technique
- TS 1 higher
- TS 2 in the range




Other Atlanta Area Tests – Unit Base Resistance



Other ATL Tests Observations – Unit Base Resistance

- Curves and calculated elastic modulus for Sites B and C compare favorably to Test Shaft 1 (UBR from test Shaft 1 = reasonable value for this material).
- Tests B and C terminated at lower nominal displacements than TS 1, but could have probably achieved similar magnitudes of UBR.
- Site A had a much softer base response than any of the other tests.



Summary of Results and Design Implications

- The test data suggest that the current rock auger refusal criteria of 2in/5min may be too restrictive.
 - Both test shafts were terminated in material that did not meet the current criteria for rock auger refusal (TS 1 = 4 to 6 in/5min; TS 2 = 3in/5min)
 - Significantly higher UBR and USR were achieved than are commonly used for design at these conditions
 - A less restrictive criterion of 5in/5min appears appropriate



Summary of Results and Design Implications

- The ultimate or strength limit state base resistance exceeds the structural capacity of typical reinforced concrete shaft.
- UBR = 60 to 150ksf was observed at a small displacement of only 0.5% D. Range is current maximum allowable values for more stringent rock criteria



Summary of Results and Design Implications

- Significant USR (over 50ksf) is available in rock that would not meet current “rock” criteria for maximum bearing.
- Significant USR (2.5 to 15ksf) is available in the PWR.



Current Practice

- Typical Factor of Safety = 2.
- Allowable base resistance ranges from 30ksf for soft PWR to 150ksf for hard rock.
- Settlement limited to ¼in, not including the elastic compression of the shaft.
- Typically design for base resistance only bearing on rock, typically defined by “rock auger refusal” as defined below. Side resistance is very rarely used.
- Allowable side resistance in PWR typically 1 to 2 ksf, in rare cases where it is used (possibly 3ksf in very hard PWR).
- Criteria for “rock auger refusal” is related to refusal using an LLDH rig at a penetration rate of 2in/5min.
- Quality of PWR/rock below rock auger refusal assessed by downhole inspection w/probe holes. The depth and thickness of seams is determined and a judgment made if the shaft needs to go deeper to get below the seams noted.



Open Discussion – Your Contribution!

Can we get consensus on 3 points?

- An allowable unit base resistance for rock equal to or better than the rock tested at this site (perhaps coin a term such as “Lawrenceville grade rock”).
- A lower-bound unit base resistance for rock with soil/PWR seams.
- Use of an allowable unit side resistance in PWR and/or rock to use the socket length plus the lower bound unit base resistance base to satisfy demand.